

TEST REPORT

| DATE: 04-25-2023 | Page 1 of 2 | TEST NUMBER : 0295655 |
|-----------------------|---|------------------------------|
| CLIENT | Lions Floor | |
| | | |
| TEST METHOD CONDUCTED | ISO 4918 Resilient, Textile and Laminate Floor Coverings - Castor Chair Test | |
| | | |

| | DESCRIPTION OF TEST SAMPLE |
|----------------|----------------------------|
| IDENTIFICATION | Comfort Heights |
| COLOR | Country Aura |
| ROLL NUMBER | SKU: LI-CH07 |
| CONSTRUCTION | Laminate Flooring |

GENERAL PRINCIPLE

This test is designed to determine what effect the action of rolling traffic has on a particular flooring surface. The sample is subjected to the reciprocating action of a chair base which is loaded with weight. The chair castors are set to cause a circular cycling motion resulting in a circle shaped wear pattern.

TEST RESULTS

| NUMBER OF CYCLES | APPEARANCE RATING |
|------------------|-------------------|
| 25,000 | No damage |

Lary atlury APPROVED BY:


This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.



TEST REPORT

| DATE: 04-25-2023 | Page 2 of 2 | TEST NUMBER : 0295655 |
|-----------------------|---|---------------------------------|
| CLIENT | Lions Floor | |
| | | |
| TEST METHOD CONDUCTED | ISO 4918 Resilient, Textile and Lam Chair Test | ninate Floor Coverings - Castor |
| | | |

| | DESCRIPTION OF TEST SAMPLE |
|----------------|----------------------------|
| IDENTIFICATION | Comfort Heights |
| COLOR | Country Aura |
| ROLL NUMBER | SKU: LI-CH07 |
| CONSTRUCTION | Laminate Flooring |



APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.

Lang atluny

Fax: 706-226-6787