TEST REPORT

CLIENT Lions Floor

TEST METHOD CONDUCTED

ASTM E662 Smoke Density (Non-Flaming) Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials



	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	District: 2mm/6mil
COLOR	Carmel
ROLL NUMBER	SKU: LI-DT07
CONSTRUCTION	LVP

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

CONDITIONS				
PREDRYING OF TEST SAMPLE	24 Hours at 140° F			
CONDITIONING OF TEST SAMPLE	24 Hours at 70° F and 50% Relative Humidity			
TESTING CONDITION	As Received			
FURNACE VOLTAGE	118 V	IRRADIANCE	2.5 watts/sq cm	
CHAMBER TEMPERATURE	95° F	CHAMBER PRESSURE	3" H ₂ O	
TEST MODE	Non-Flaming			

AVERAGE MAXIMUM DENSITY CORRECTED	(Dmc)	NON-FLAMING	307
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			210
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	265.0	332.0	326.0
Time to Dm (minutes)	10.5	8.0	7.5
Clear Beam (Dc)	1.0	2.0	0.0
Corr. Max Density (Dmc)	264.0	330.0	326.0
Density at 1.5 minutes	18.0	33.0	17.0
Density at 4.0 minutes	132.0	247.0	252.0
Time to 90% Dm (minutes)	7.0	5.0	5.0
Specimen Weight (grams)	21.2	21.5	21.7

APPROVED BY:


TESTING NUMBER OF THE TOTAL OF

Lary asbury

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place Dalton, GA 30721 706-226-3283 Fax: 706-226-6787 protest@optilink.us



TEST REPORT

CLIENT Lions Floor

TEST METHOD CONDUCTED

ASTM E662 Smoke Density (Non-Flaming) Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials

DESCRIPTION OF TEST SAMPLE		
IDENTIFICATION	District: 2mm/6mil	
COLOR	Carmel	
ROLL NUMBER	SKU: LI-DT07	
CONSTRUCTION	LVP	



APPROVED BY:

This facil Lab Cook United Si

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place Dalton, GA 30721

Dary asbury

706-226-3283

Fax: 706-226-6787 protest@optilink.us